

HOKKAIDO UNIVERSITY

Title	Effect of Temperature Gradient in Ash on High-Temperature Corrosion of Super-Heater Material in a Waste Power Generation Boiler
Author(s)	Furugaki, T.; Takahashi, H.; Hayashi, S.
Citation	Oxidation of metals, 98(5-6), 511-528 https://doi.org/10.1007/s11085-022-10135-1
Issue Date	2022-12
Doc URL	http://hdl.handle.net/2115/90597
Rights	This version of the article has been accepted for publication, after peer review (when applicable) and is subject to Springer Nature 's AM terms of use, but is not the Version of Record and does not reflect post-acceptance improvements, or any corrections. The Version of Record is available online at: http://dx.doi.org/10.1007/s11085-022-10135-1
Туре	article (author version)
File Information	manuscript_rev (Hayashi).pdf



Instructions for use

Effect of Temperature Gradient in Ash on High-Temperature Corrosion of Super-Heater Material in a Waste Power Generation Boiler

T. Furugaki, H. Takahashi, S. Hayashi

T. Furugaki

Takuma Co., LTD, 2-2-33, Kinrakuji-cho, Amagasaki, Hyogo 660-0806, JAPAN e-mail: furugaki@takuma.co.jp

H. Takahashi

Takuma Co., LTD, 2-2-33, Kinrakuji-cho, Amagasaki, Hyogo 660-0806, JAPAN e-mail: hiromitu@takuma.co.jp

S. Hayashi

Faculty of Engineering, Division of Materials Science and Engineering, Hokkaido University, Kita13 Nishi8, Sapporo 060-8628, JAPAN e-mail: hayashi@eng.hokudai.ac.jp

keywords

high-temperature corrosion, temperature gradient, ash, alkali salt vapor, heat-resistant steel, Cr-rich oxide scale

Statements and Declarations

No funding was received for conducting this study.

The authors declare that they have no conflict of interest.

Author contribution

T. Furugaki, H. Takahashi, S. Hayashi: Conception and design of study.

T. Furugaki: Acquisition of data.

T. Furugaki, S. Hayashi: Analysis and/or interpretation of data.

T. Furugaki: Drafting the manuscript.

- T. Furugaki, S. Hayashi: Revising the manuscript critically for important intellectual content.
- H. Takahashi, S. Hayashi: Approval of the version of the manuscript to be publish.

Abstract

The effect of the temperature gradient in ash deposition on the high-temperature corrosion behavior of heat-resistant steels used for super-heater tubes in a Waste-to-energy (WTE) boiler plant was investigated by conducting ash embedded corrosion tests using combustion ash from the actual boiler. The ash embedded corrosion test was carried out under two conditions: 1) an isothermal corrosion test at 460 °C, and 2) a temperature gradient corrosion test with a specimen temperature of 460 °C and an atmospheric temperature of 685 °C in air. The corrosion mass loss was found to be much greater under higher atmospheric temperatures where the same specimen temperature was maintained than under the same atmospheric temperature gradient corrosion test revealed that the alkali salt mixture was melted in the region above the melting point of the ash, however, no penetration of the melt reaching to the specimen surface was confirmed, suggesting that the corrosion was produced by a gas-solid reaction. Thus, the faster corrosion kinetics of the heat-resistant steels under an ash deposit with a vapor of alkali salts to form less protective alkaline chromates. The difference in the potentials of the alkali salt across the ash deposit due to the temperature gradient could be the driving force that increases the flux of the alkali salts towards the specimen surface, which accelerates the formation of chromates and the rate of breakdown of the protective Cr-rich oxide scale.

1. Introduction

Waste power generation and biomass power generation play an important role in energy supply. Due to a reduction in the power generated by fossil fuel combustion, the importance of WTE plants is now increasing. Higher steam temperature is one of the crucial requirements to increase the efficiency of WTE plants. However, the steam temperature in current WTE plants is much lower than that in fossil fuel power plants because of the high-temperature corrosion of components used in the boiler. Super-heater tubes used in waste incineration plants are exposed to extremely corrosive environments, which contain corrosive gas. Combustion ash, which contains alkaline salts and heavy metal salts, also accelerates corrosion through deposition on the surface of super-heater tubes during service. In such a severely corrosive environment, various coatings are used to protect the super-heater tubes of WTE plants, which are typically made from Type 310 heat-resistant steel.^[1-4]

It is well known that enhanced oxidation degradation, so called "active oxidation", occurs on oxidation resistant alloys in chlorine-containing atmospheres due to simultaneous oxidation and chlorination reactions within the oxide scale when chlorine penetrates the oxide scale to the metal/oxide scale interface. Under "active oxidation", metal chlorides generated by chlorination of a metal substrate or oxides within the oxide scale where the oxygen potential is sufficiently low are oxidized to form a very porous, sponge-like oxide scale that is less protective. Once active oxidation takes place, rapid corrosion continues to progress even if chlorine is not continuously supplied from the gas atmosphere. This situation accelerates the oxidation/corrosion of alloys. ^[5-7]

An external chromium oxide (Cr_2O_3) has the ability to protect steel against chlorination atmospheres to some extent. However, over the long term, it loses its protective function. While the routes by which chlorine penetrates the metal/oxide scale interface still require elucidation, one route has been reported to be via cracks and pores in the Cr oxide scale ^[4]. Moreover, it has also been shown that in a harsh environment characterized by high gas and steam temperatures, the protective Cr oxide scale is destroyed by corrosive factors, such as alkali chlorides. Alkali chlorides have also been reported to form alkali chromates by reacting with Cr_2O_3 scale, which also decreases the protective ability of the Cr-rich oxide scale. ^[8-14]

Under the operational conditions of the boiler, heat-resistant steels used for super-heater tubes are exposed to an extremely corrosive environment containing several corrosive gas species such as HCl, SO₂, O₂, H₂O, and CO₂. The combustion ash, which is mainly composed of various salts, deposited on the surface of tubes is also known to accelerate corrosion. ^[15] Many studies have evaluated the corrosion behavior of heat-resistant steels and alloys in various ash embedding conditions, however, "most these studies were conducted as a crucible test", in which the samples were embedded in the ash or various salt mixtures in a crucible and exposed isothermally to different temperatures. In an actual boiler, because of differences in the temperatures in the atmosphere and steam, a large temperature gradient exists across the ash deposited on a super-heater tube. Reports show that this temperature gradient accelerates the corrosion ^[16], however, the role of the temperature gradient on the corrosion behavior of heat resistant steels and alloys is yet to be fully clarified. In this study, corrosion tests were conducted using combustion ash collected from an actual super-heater tube, and the effect of the temperature gradient in the ash on the high-temperature corrosion behavior of steels was investigated.

2. Experimental procedures

2.1. Sample preparation

Specimens for corrosion tests were cut from commercial SUS310S and QSX5 steel tubes into $10 \times 10 \times 1$ mm coupons. All specimen surfaces were polished with a SiC paper up to 4000 grits and finished with a 3 μ m diamond paste. Before corrosion tests, the specimens were ultrasonically degreased and cleaned in acetone for 10 min. Nominal compositions of the steels used are shown in Table 1.

2.2. Combustion ash

In this study, combustion ash deposited on the surface of super-heater tubes in an actual waste incineration boiler was used in the corrosion tests. Figure 1 shows a schematic cross-section of the combustion ash deposited on a super-heater tube, and Table 2 shows the composition of the combustion ash sampled at different depths of the deposit by XRF (X-ray fluorescence). The alkali chloride content in the tube side ash was much higher at 31.3 mass% in comparison to the gas side ash at 11.4 mass%. Conversely, the oxide content in the gas side ash was higher than that in the tube side ash. Of these ash samples, the tube side ash, which was rich in alkali salts and highly corrosive, was used for the corrosion tests. The melting point of the tube side ash was confirmed by TG-DTA to be 519°C.

2.3. Corrosion tests

Corrosion tests were performed in a furnace in air for 100 h. Tests were conducted either isothermally, where the atmosphere and specimens were set to the same temperature, or non-isothermally, i.e., the temperature of the atmosphere was set higher than that of the specimens. The isothermal corrosion tests were performed in a box furnace at 460 °C, as illustrated in Figure 2(a). The specimens were embedded in the ash at a depth of 10 mm from the ash surface in an Al_2O_3 crucible. The non-isothermal corrosion tests were performed in an open horizontal tube furnace, as illustrated in Figure 2(b). The specimens were embedded in the ash at a depth of 10 mm from the specimen holder and cooled by

feeding steam into the specimen holder. During corrosion tests, the temperature of the atmosphere was set to 685 °C and that of the specimens was set to 460 °C. The temperature was monitored by thermocouples inserted in the reaction tube and the specimen holder.

At least two specimens of each type of steel underwent corrosion in each corrosion test. After the corrosion test, corrosion products formed on the one of the two specimens were removed by chemical treatment according to ISO 17248:2015E (see Table 3). The mass change of each specimen was evaluated by measuring the mass of specimens before corrosion and after the removal of oxide scale/corrosion products by chemical treatment. The other specimen was mounted in epoxy resin, then cut and polished using oil in order to prevent dissolution of reaction products in water. The crosssection of the specimens was examined by scanning electron microscopy (SEM, JEOL JSM-IT200) with an accelerating voltage of 15kV and electron probe micro-analyzer (EPMA, JEOL JXA-8530F) with an accelerating voltage of 15 kV to determine the microstructure and elemental distribution of the corrosion products. The specimens were also analyzed using X-ray diffraction (XRD; Rigaku SmartLab) to confirm the structural phases of the corrosion products. The XRD patterns were measured in Bragg-Brentano geometry using Cu-k α 1 radiation ($\lambda = 1.5405$ nm) in the range of 20° - 90° with a step size of 0.01 and 4 s per step. The analysis of XRD profiles was performed using QualX2 software with the POW COD database for phase identification. In order to confirm the distribution of alkaline chlorides in the ash after the temperature gradient corrosion test, ash cross-sections, which were non-heated or heated at 685°C in a crucible with a lid for 2 h, and after a temperature gradient corrosion test for 100 h, were analyzed by SEM and energy dispersive spectroscopy (EDS). The temperature distribution in the ash was also measured using K-type thermocouples inserted in the ash at different depths (1, 3 and 7 mm) from the specimen surface.

3. Results

3.1. Surface morphology of specimens after corrosion

Figure 3 shows the surface appearance of the specimens after undergoing corrosion for 100 h. After the isothermal corrosion test, localized areas of the specimen surface changed to a bright brown color, and the metallic regions with interference color remained in other areas. In addition, the bright brown corroded areas appear to extend around those places where ash had accumulated. On the other hand, after the temperature gradient corrosion test, the corroded areas extended over the entire surface of the specimens with the corrosion products appearing as a dark brown color. Yellow and green colored reaction products can also be locally observed on the dark brown colored corrosion products combined with the white ash. These corrosion products are presumed to be Fe-rich oxides and Ca chromate, as described below.

3.2. Corrosion mass change

Figure 4 shows the mass loss of specimens after undergoing corrosion for 100 h. The corrosion mass loss of both steels was small in the isothermal corrosion test, but the mass loss of SUS310S tended to be greater than that of QSX5. However, in the temperature gradient corrosion test, it is obvious that the corrosion mass loss of SUS310S was much greater than that of QSX5, and the corrosion mass loss of both steels was more than 10 times greater than that which occurred during the isothermal corrosion test. This finding indicates that the temperature gradient in the ash accelerates the corrosion rate even though the specimen temperature is the same.

3.3. Cross-sectional observation and analysis of specimens after corrosion

Figure 5 shows the cross-sections of the specimens after corrosion for 100 h. A thin oxide scale formed on part of the specimen surface, but no penetration of corrosion products into the specimen can be observed following the isothermal corrosion test as shown in Figures 5(a), (b). However, almost the entire surface of both specimens became covered by a thick oxide scale following the temperature gradient corrosion test. Significant inward attack by can be observed in SUS310S and the surface of the specimen became very rough due to local penetration of corrosion products, as shown in Figure 5(c). However, such penetration of corrosion products was not clearly evident on the QSX5 specimen as shown in Fig. 5(d). This finding suggests that QSX5 has higher resistance to corrosion than SUS310S under the corrosion conditions present in this test.

Figure 6 shows enlarged cross-sections of the specimen following the temperature gradient corrosion test for 100 h. The scale structure was similar for both steels, and the scale formed on the steels can be divided into two parts. The outer part of the oxide scale is very porous, and the ash has been incorporated into the oxide scale. The inner part of the oxide scale has a layer-by-layer structure and appears to penetrate into the alloy substrate.

Figure 7 shows an electron probe microanalyzer (EPMA) map of each element in the oxide scale that formed on the SUS310S specimen after the temperature gradient corrosion test for 100 h. Although chlorine was detected over a wide area in the oxide scale, this might be due to contamination from the remaining ash and which occurred during polishing by oil. The regions where a strong chlorine signal was detected mainly corresponded to the ash, thus it was difficult to confirm chloride formation in the corrosion product based on this EPMA analysis. The outer porous oxide scale mainly consisted of an Fe-rich oxide and Cr is also detected in the Fe-rich oxide scale. The inner scale with a layer-by-layer structure mainly consisted of Cr-rich oxide but Ni+Fe oxides were also detected. Ca, K and Na were found not only in the ash but also in the areas of Cr oxide in the outer and inner oxide scale, suggesting that alkaline chromates had formed. Figure 8 shows the EPMA maps of each element in the oxide scale formed on the QSX5 specimen after the temperature gradient corrosion test for 100 h. The outer porous oxide scale consisted of mainly Fe-rich oxide, which contains a relatively high Ni content. Cr oxide was also observed locally below the outer Fe-rich oxide scale. Ca and Na were also detected in the inner Cr-rich oxide scale. K was mainly detected in the ash area. The inner scale with a layered structure mainly consisted of Cr-rich oxide scale of the ash area. The inner scale with a layered structure mainly consisted of Cr-rich oxide scale in the ash area. The inner scale with a layered structure mainly consisted of Cr-rich oxide, but Fe, Ni, Mo, and Si were also detected. Indistinct chlorine distribution in the oxide scale in Figure 8 could be also due to contamination during specimen preparation as mentioned above.

3.4. Characterization of corrosion products by XRD

Figure 9 shows X-ray diffraction patterns of the SUS310S and QSX5 specimens after the temperature gradient corrosion test for 100 h. In the case of the SUS310S, γ -Fe from the substrate, Fe₂O₃, and Cr₂O₃ were identified from the main scale component, and Na, and Ca chromates, which were confirmed by EPMA, were also identified but K chromate was not detected. γ -Fe, Fe₂O₃, Cr₂O₃, Ca chromate, and the ash components NaCl, and KCl were also identified in the QSX5 specimen, however, Na and K chromates were not found even though they were detected by EPMA. It is possible that the amounts of those corrosion products formed on the QSX5 specimen were too small to be detected by conventional XRD.

3.3. Cross-sectional observation and analysis of ash

Figure 10 shows cross-sections of the ash. The first (a) shows a non-heated cross-section, the second (b) after being heated

in a crucible with a lid at 685 °C for 2 h, and the third (c) after the temperature gradient corrosion test for 100 h. The ash before heating consisted of different sized particles and components with bright contrast were dispersed in the particles. After heating at 685 °C for 2 h, the ash became dense due to partial melting. As shown in Figure 11, the Cl concentration in the heated ash was increased to about 41%, which is higher than that of that non-heated ash, 25.5%, which might be due to densification of the ash. The ash cross-section after the temperature gradient corrosion test showed a three-layered structure in the depth direction. In region 1 on the specimen side (bottom), the ash contrast was bright and porous, but the ash became dense in region 2, which was similar to heated ash at 685 °C for 2 h, and bright contrast precipitates were present. The ash in the region 3 (atmospheric side) was porous and similar to that of non-heated ash. Figures 11 and 12 show the concentration distributions of Ca, Na, K, and Cl and the temperature distribution of the ash in the depth direction after the temperature gradient corrosion test. The concentration of K, Na, and Cl is highest in region 2. The Cl concentration in regions 2 and 1 was higher than that of non-heated ash. However, the concentrations of Na, K, and Cl in region 3 gradually decreased towards the ash surface. Because the concentration of Ca was almost constant across the ash deposition, most of the alkali salts diffused from the melted region 2 as a vapor in both the surface and bottom directions. The vapor of salts diffused to the ash surface should be lost to the atmosphere during a corrosion test. However, the vapor of alkali salts diffused inwardly to the bottom side, the temperature of which is lower than the melting point, and this might contribute to the acceleration of the steel corrosion rate.

4. Discussion

<Breakdown of protective Cr2O3 scale>

The corrosion mass change of both steels as a result of the temperature gradient corrosion test was much larger than that by the isothermal corrosion test. Both steels formed a very thin oxide scale after the isothermal corrosion test. However, the steel surface was covered by a thick and porous duplex oxide scale when the steels were exposed to the ash with a temperature gradient. Since the temperature of the specimens was kept at 460 °C, which is lower than the melting point of the ash in both corrosion tests, steels were corroded by corrosive gas species with the same oxygen, chlorine, and salt potentials. Therefore, the temperature gradient in the ash in which the specimen was embedded has a potent effect on accelerating corrosion. The thick corrosion products formed after the temperature gradient corrosion test consisted of an outer scale of Fe-rich oxide incorporating ash components and an inner scale of Cr-rich oxide which was a layer-by-layer structure. It has been reported that SUS310S and QSX5 steels form a protective Cr_2O_3 scale in air and O_2 ^[15]. In the present study, a thin protective Cr-rich oxide scale was also confirmed to form locally after 100 h of corrosion when the steels were exposed in an isothermal corrosion test. Although a short-term oxidation test was not conducted in this study, it is reasonable to assume that a protective Cr-rich oxide scale was formed on both steels during the initial stage of corrosion. Then the initial protective corrosion behavior transitioned to a less protective corrosion behavior once the protective Cr-rich oxide scale was converted to corrosion products that were less protective. This transition behavior can be observed from the surface appearance shown in Figs. 3(a) and (b) that the interference-colored area with thin oxide scale regions changed to a bright-brown colored region. It is assumed therefore that the temperature gradient in ash shifts this transition time to a shorter corrosion time.

Figure 13 shows phase stability diagrams of Fe-Cl-O, Cr-Cl-O, and Ni-Cl-O at 460 °C. Fe, Cr, and Ni in Figure 13 were calculated from the activity of those elements in the Fe-25Cr-20Ni alloy using FactSage software. The chloride

region in the figures includes a gas phase having a vapor pressure of 10^{-4} atm or more. The equilibrium chlorine potential when the combustion ash was held at 460 °C in the air is given by Formula (1) from the calculation using the FactSage software.

$$P_{Cl_2}(T = 460^{\circ}C) = 8.1 \times 10^{-9} atm (1)$$

On the assumption that a Cr_2O_3 scale was formed initially, the oxygen potential at the scale/metal interface decreases to $P_{O2} = 10^{-44}$ atm according to Formula (2) with the Cr activity, aCr = 0.28.

$$4/3Cr(s) + O_2(g) = 2/3Cr_2O_3(s)$$
 (2)

The free-energy changes in chloride formation for each element given in Formulas (3) - (6) calculated with the chlorine potential in Formula (1) and the activities of the elements in the alloy under the assumption that the chlorine potential across the Cr_2O_3 scale does not change significantly ^[15]. All metal components can be chloridized under a low oxygen potential below the Cr_2O_3 oxide scale.

$$Fe(s) + Cl_{2}(g) = FeCl_{2}(s) (3)$$

$$\Delta G^{0}(T = 460^{\circ}C) = -246kj$$

$$2Fe(s) + 3Cl_{2}(g) = 2FeCl_{3}(s) (4)$$

$$\Delta G^{0}(T = 460^{\circ}C) = -162kj$$

$$Cr(s) + Cl_{2}(g) = CrCl_{2}(s) (5)$$

$$\Delta G^{0}(T = 460^{\circ}C) = -299kj$$

$$2Cr(s) + 3Cl_{2}(g) = 2CrCl_{3}(s) (6)$$

$$\Delta G^{0}(T = 460^{\circ}C) = -242kj$$

The formation of chlorides at the scale/steel interface can cause the protective Cr_2O_3 scale to peel off due to loss of contact between scale and alloy, so one of the main factors that reduces the protectiveness of the Cr_2O_3 scale is scale exfoliation. In fact, some exfoliation was observed on a thin oxide scale formed on the specimen surface after the isothermal corrosion test as shown in Figure 5. However, visible internal chlorination was not observed in either type of steel. Because no Cr depleted region was observed in the subsurface region of steels from the EPMA mapping, even if such scale exfoliation occurs, Cr-rich oxide scale can reform in the region where the exfoliation occurs. In addition, with this model there is no clear explanation that the temperature gradient in the ash accelerated the spallation of the protective oxide scale. Thus, scale exfoliation/spallation due to the formation of chlorides cannot be the main reason for accelerated corrosion under the temperature gradient test.

From the EPMA analysis results in Figs. 7, 8 and XRD in Fig. 9, the formation of chromates was confirmed. The vapor pressures of NaCl and KCl in the combustion ash at 460 °C were calculated using FactSage as $P_{NaCl} = 3.53 \times 10^{-9}$ atm and $P_{KCl} = 1.05 \times 10^{-8}$ atm, respectively. Then, the free-energy changes of K₂CrO₄ or Na₂CrO₄ formation by formulas (7) and (8) were calculated with chlorine and oxygen potential in the atmosphere, P_{Cl2} (T = 460°C, in the atmosphere) = 8.1×10⁻⁹ atm and P₀₂=0.2 atm as $\Delta G_{K2CrO4} = -18$ kJ, and $\Delta G_{Na2CrO4} = -26$ kJ, respectively.

$$2/5Cr_2O_3(s) + 8/5KCl(g) + O_2 = 4/5K_2CrO_4(s) + 4/5Cl_2 (7)$$
$$\Delta G^0(T = 460^\circ C) = -54 \text{ kJ}$$
$$2/5Cr_2O_3(s) + 8/5NaCl(g) + O_2 = 4/5Na_2CrO_4(s) + 4/5Cl_2 (8)$$
$$\Delta G^0(T = 460^\circ C) = -62 \text{ kJ}$$

Once alkali chromates were formed, the Cr_2O_3 scale loses its protectiveness. Even if sufficient Cr remains in the alloy and a Cr_2O_3 scale is reformed below the chromate scale, a reformed Cr_2O_3 scale might react with salt vapors to form chromates again. Thus, formation of chromates could be the main reason for the long-term corrosion resistance of steels being reduced in salt vapor-containing atmospheres. Izzuddin et al. proposed a similar model for the corrosion behavior of Ni-Cr alloys in alkaline salt vapor environments ^[14]. When the reactions of Formulas (7) and (8) proceeded, the chlorine potential near the chromate surface is increased. The equilibrium chlorine potentials for the reactions of Formulas (7) and (8) are given by Formulas (9) and (10), respectively. The chlorine potentials are higher than that in the atmosphere (Formula (1)), which might accelerate the chlorination of steels below the less protective chromate scale.

$$P_{Cl_2} eqK_2CrO_4 = 2.0 \times 10^{-6} atm (9)$$
$$P_{Cl_2} eqNa_2CrO_4 = 3.4 \times 10^{-7} atm (10)$$

Once metal chlorides were formed, they volatilized below the chromate scale due to the high vapor pressure according to Formula (11), and the volatilized metal chlorides were then oxidized to form a porous outer oxide scale in a region of sufficient oxygen potential according to Formula (12) and released chlorine.

$$MCl_{2}(s) = MCl_{2}(g) (11)$$

$$4/3MCl_{2}(g) + O_{2} = 2/3M_{2}O_{3}(s) + 4/3Cl_{2} (12)$$

This chlorination-oxidation cycle, which is referred to as active oxidation, causes rapid consumption of the steel matrix without the need to supply chlorine from the atmosphere ^[5-7].

<Effect of temperature gradient across the ash>

Formation of a molten layer with a high concentration of the alkali salt in the area where the temperature was higher than the melting point of the ash was confirmed from the cross-section of the ash after the corrosion test. The higher concentration of chloride/salts closer to the specimen surface than the original ash component was also confirmed, which suggests that the alkali salt vapor diffused to the low temperature region towards the specimen surface from the molten layer. Different potentials of salt vapor near the specimen surface and a molten layer could be the driving force for salt vapor flux to the surface of the specimen. Thus, it is apparent that the temperature gradient in the ash acted as the driving force to increase the flux of the alkali salt vapor from the molten layer to the specimen surface. The increase in the flux of alkali salt vapor under the temperature gradient corrosion condition could accelerate the rate to extend the area of chromate scale, i.e., the rate of breakdown of the protective Cr_2O_3 scale. The protective Cr_2O_3 scale rapidly changed to a chromate scale, resulting in a shorter transition time to the less protective corrosion stage with a rapid rate of steel consumption.

Figure 14 is a schematic representation of the corrosion behavior of heat-resistant steels in a temperature gradient corrosion test. At the initial corrosion stage, a protective Cr-rich oxide scale is formed on the surface of the specimen, and the melts is formed in the temperature range above the melting point of the ash. The alkali salt vapor diffuses from the molten layer to the surface of the specimen as shown in Figure 14 (1). Alkali salt vapors react with the Cr-rich scale to form Na and K chromates (the breakdown of the protective Cr-rich scale, Figure 14 (2)). The chlorine partial pressure increases due to the chromate formation reaction, and more metal chloride is formed and volatilized at the scale/metal interface (Figure 14 (3)). Once the breakdown areas cover the entire surface of the specimen within a short time, the entire surface becomes covered by a porous Fe oxide and the layer-by-layered inner layer is formed (Figure 14 (4)). Deposite-induced corrosion as this study is described as occurring in two stages: an "incubation stage" in which corrosion is slow and then a "propagation stage" in which corrosion is rapid ^[17]. Therefore, it is presumed that the corrosion rate of heat-resistant steel changes rapidly due to the breakdown of the Cr2O3 scale.

In this experiment, QSX5 demonstrated higher corrosion resistance than SUS310S. The content of Mo and Si is higher in QSX5. The formation and maintenance of the protective Cr_2O_3 scale is known to be improved by the addition of Si due to formation of a SiO₂ layer below the Cr_2O_3 scale ^[18]. The addition of Mo to Ni-Cr alloys was also reported to promote a Cr_2O_3 scale and reduce the rate of high temperature oxidation ^[19]. Therefore, it is presumed that the higher corrosion resistance of QSX5 compared to SUS310S can be attributed to the effects of adding Si and/or Mo, but further detailed studies are needed to clarify the effects of these elements.

5. Conclusion

The effect of the temperature gradient in the ash on the corrosion resistance of super-heater tube material was investigated. The obtained results can be summarized as follows:

- (1) The corrosion mass loss after temperature gradient corrosion at a high atmospheric temperature was greater than that after isothermal corrosion, even where the temperature of the specimen was the same. In both corrosion tests, QSX5 showed higher corrosion resistance than SUS310S.
- (2) The corrosion behavior can be explained as a chlorination induced accelerated oxidation after the breakdown of the protective Cr-rich oxide scale. The Cr-rich oxide scale lost its protective ability due to the formation of alkali chromates caused by a reaction between the protective Cr-rich scale and the alkali salt vapor.
- (3) The effect of the temperature gradient in the ash is to accelerate the breakdown of the Cr-rich scale by increasing the flux of the alkali salt vapor from the molten layer to the specimen surface.

Acknowledgment

A part of this work was conducted at the Hokkaido University, supported by "Nanotechnology Platform Program" of the Ministry of Education, Culture, Sports, Science and Technology (MEXT), Japan, Grant Number JPMXP09A21HK0064.

References

 Zuopeng Qu, Rigang Zhong, Lei Wang, Wenbo Zhao, Xinli Tian and Haijun Wang, High Temperature Corrosion Protection of Heating Surface Metals of Waste Incineration Power Generation Boilers: A Review, Journal of Physics: Conference Series 1649 (2020) 012031

[2] Jaswinder Singh, Hitesh Vasudev, Sharanjit Singh, Performance of different coating materials against high temperature oxidation in boiler tubes – A review, Materials Today: Proceedings · January 2020

[3] Wei Wang, Zongde Liu, Principle and protective measures of high temperature corrosion of garbage incineration boiler, Journal of Physics: Conference Series 1635 (2020) 012087

[4] Kawahara, High temperature corrosion mechanisms and effect of alloying elements for materials used in waste incineration environment, Corrosion Science 44 (2002) 223-245

[5] Shang-Hslu, Nickolas J. Themells, Marco J. Castaldi, High Temperature corrosion in Waste-to-Energy Boilers, Journal of Thermal Spray Technology volume 16(1) March 2007

[6] J. M. OH, M. J. McNALLAN, G. Y. LAI, M. F. ROTHMAN, High temperature Corrosion of Superalloys in an Environment Coating Both Oxygen and Chlorine, METALLUGICAL TRANSACTIONS A, volume 17A, June 1986 1087-1094

[7] Zuopeng Qu, Rigang Zhong, Lei Wang, Wenbo Zhao, Xinli Tian and Haijun Wang, Research Progress on High Temperature Corrosion Mechanism of Waste Incineration Power Generation Boiler, Earth and Environmental Science 598 (2020) 012008

[8] J. Phother-Simon*, T. Jonsson, J. Liske, Continuous KCl addition in high temperature exposures of 304 L – A way to mimic a boiler environment, Corrosion Science 167 (2020) 108511

[9] S. Karlsson, J. Pettersson, L. -G. Johansson, J. -E. Svensson, Alkali Induced High Temperature Corrosion of Stainless Steel: The Influence of NaCl, KCl and CaCl₂, Oxid Met (2012) 78:83–102

[10] Jesper Pettersson, Nicklas Folkeson, Lars-Gunnar Johansson, Jan-Erik Svensson, The Effects of KCl, K₂SO₄ and K₂CO₃ on the High Temperature Corrosion of a 304-Type Austenitic Stainless Steel, Oxid Met (2011) 76:93–109

[11] Kent O. Davidsson, Lars-Erik Åmand, Bo Leckner, Potassium, Chlorine, and Sulfur in Ash, Particles, Deposits, and Corrosion during Wood Combustion in a Circulating Fluidized-Bed Boiler, Energy & Fuels 2007, 21, 71-81

[12] Sofia Karlsson, Lars-Erik Åmand, Jesper Liske, Reducing high-temperature corrosion on high-alloyed stainless steel superheaters by co-combustion of municipal sewage sludge in a fluidised bed boiler, Fuel 139 (2015) 482–493

[13] J. Eklund, A. Persdotter, I. Hanif, S. Bigdeli, T. Jonsson, Secondary corrosion protection of FeCr(Al) model alloys at 600 °C – The influence of Cr and Al after breakaway corrosion, Corrosion Science 189 (2021) 109584

[14] Hubby Izzuddin, Shigenari Hayashi, Suzue Yoneda, Takashi Kogin, Eiji Ishikawa, Manabu Noguchi, Effect of Mo on corrosion behavior of Ni20Cr-xMo alloys in air with NaCl-KCl-CaCl₂ vapor at 570°C, Materials and Corrosion. 2020; 1-12

[15] David J. Young, High Temperature oxidation and corrosion of Metals, 2016.

[16] Bernard S. Covino, Jr., James H. Russell, Stephen D. Cramer, et al., The Role of Ash Deposits in the High Temperature Corrosion of Boiler Tubes, Conference: Corrosion 2003, Paper No. 3718

[17] N. Birks, G. H. Meier, and F. S. Pettit, Introduction to High Temperature Oxidation of Metals, 2nd Edition, Cambridge University Press, Cambridge, 2006

[18] H. E. Evans, D. A. Hilton, R. A. Holm, and S. J. Webster, Influence of Silicon Additions on the Oxidation Resistance of a Stainless Steel, Oxidation of metals, Vol. 19, Nos. 1/2, 1983

[19] Si-Jun Park, Seong-Moon Seo, Young-Soo Yoo, Hi-Won Jeong and HeeJin Jang, Effects of Cr, W, and Mo on the High Temperature Oxidation of Ni-Based Superalloys, Materials 2019, 12, 2934

Caption List

Figure 1 Schematic cross-section of combustion ash deposited on super-heater tube

Figure 2 Schematic of corrosion equipment:

(a) isothermal corrosion test, (b) temperature gradient corrosion test

Figure 3 Surface observations of specimen after corrosion for 100 h:

(a) SUS310S after isothermal corrosion test, (b) QSX5 after isothermal corrosion test,

(c) SUS310S after temperature gradient corrosion test, (d) QSX5 after temperature gradient corrosion test

Figure 4 Mass loss after corrosion for 100 h

Figure 5 Cross-sections after corrosion for 100 h:

(a) SUS310S after isothermal corrosion test, (b) QSX5 after isothermal corrosion test,

(c) SUS310S after temperature gradient corrosion test, (d) QSX5 after temperature gradient corrosion test

Figure 7 Cross-sections after temperature gradient corrosion test for 100 h:

(a), (b) and (c) SUS310S, (d), (e) and (f) QSX5

Figure 7 Elemental distribution maps of the cross-section of SUS310S after temperature gradient corrosion test

Figure 8 Elemental distribution maps of the cross-section of QSX5 embedded in the tube side ash after corrosion

Figure 9 X-ray diffraction profiles of SUS310S and QSX5 after 100h of temperature gradient corrosion Figure 10 Ash cross-sections:

(a) non-heating, (b) after heating with lid at 685 °C in air (c) after temperature gradient corrosion test Figure 11 Cross-sectional concentration distribution of ash by EDS after temperature gradient corrosion test

(1) Cl concentration at 685°C with lid for 2h, (2) Cl concentration on non-heating

Figure 12 Temperature distribution of the ash during temperature gradient corrosion test

Figure 13 Quasi-stability diagram for the Fe-25Cr-20Ni system at 460 °C with $a_{Fe} = 0.62$, $a_{Cr} = 0.28$, $a_{Ni} = 0.11$, $P_{O2} = 0.2atm$

Figure 14 Schematic of corrosion model in the combustion ash containing alkali salt in the air

Table list

Table 1 Chemical composition of super-heater tube materials Table 1

Table 2 Ash composition by XRF

Table 3 Chemical treatment procedure based on ISO 17428:2015(E)

		1	1	(,
	Si	Mo	Ν	Cr	Ni	Fe
SUS310S	≦1.50	_	_	24.0 ~ 26.0	19.0~22.0	Bal.
QSX5	2.50~3.50	1.00~2.00	0.042	24.0~26.0	22.0~25.0	Bal.

Table 1 Chemical composition of super-heater tube materials (nominal in mass%)

							1	•	/	(,				
	Ca	0	Cl	Κ	Si	S	Na	Al	Ti	Fe	Mg	Zn	С	Pb	Ca:Na:K
tube side	20.7	19.0	31.3	9.5	1.8	2.9	9.6	1.5	0.7	0.5	0.7	0.6	0.0	0.05	2:1:1
gas side	28.6	34.3	11.4	3.0	3.8	3.6	2.6	3.6	1.6	1.2	1.5	0.7	2.3	0.03	10:1:1

Table 2 Ash composition by XRF (in mass%)

	1			
	Chemical agents	Time (min)	Temperature	
Step 1	90 g of sodium hydroxide (NaOH) 15 g of potassium	30	Boiling	
	permanganate $(KMnO_4)$ distilled water to make 500 ml	30		
Step 2	50 g ammonium citrate $((NH_4)_2C_2H_6O_7)$ distilled water to make	20	Boiling	
	500 ml	30		

Table 3 Chemical treatment procedure based on ISO 17428:2015(E)



Figure 1 Schematic cross-section of combustion ash deposited on super-heater tube





Figure 2 Schematic of corrosion equipment: (a) isothermal corrosion test, (b) temperature gradient corrosion test



0.2mm

Figure 3 Surface observations of specimen after corrosion for 100 h:

(a) SUS310S after isothermal corrosion test, (b) QSX5 after isothermal corrosion test,

(c) SUS310S after temperature gradient corrosion test, (d) QSX5 after temperature gradient corrosion test



Figure 4 Mass loss after corrosion for 100 h



Figure 5 Cross-sections after corrosion for 100 h:

(a) SUS310S after isothermal corrosion test, (b) QSX5 after isothermal corrosion test,

(c) SUS310S after temperature gradient corrosion test, (d) QSX5 after temperature gradient corrosion test



Figure 7 Cross-sections after temperature gradient corrosion test for 100 h: (a), (b) and (c) SUS310S, (d), (e) and (f) QSX5



Figure 7 Elemental distribution maps of the cross-section of SUS310S after temperature gradient corrosion test



Figure 8 Elemental distribution maps of the cross-section of QSX5 embedded in the tube side ash after corrosion



Figure 9 X-ray diffraction profiles of SUS310S and QSX5 after 100h of temperature gradient corrosion



Figure 10 Ash cross-sections:

(a) non-heating,

(b) after heating with lid at 685 ° C in air

(c) after temperature gradient corrosion test



Figure 11 Cross-sectional concentration distribution of ash by EDS after temperature gradient corrosion test

- (1) Cl concentration at 685° C with lid for 2h
- (2) Cl concentration on non-heating







Figure 13 Quasi-stability diagram for the Fe-25Cr-20Ni system at 460°C with $a_{Fe} = 0.62$, $a_{Cr} = 0.28$, $a_{Ni} = 0.11$, $P_{O2} = 0.2$ atm



Figure 14 Schematic of corrosion model in the combustion ash containing alkali salt in the air